



SGS**시험 성적서**

발행번호 : **SGS-R22-2333-KR00**
 접수번호 : **DTRI2210000013SE**
 의뢰기관 : 주식회사솔라에스티
 회사주소 : 세종특별자치시 부강면 시목부강로 278
 제품명 : 3면타공각판과 패널결합 내진시험
 모델명 : SP-E3
 시험일자 : 2022년 10월 14일
 시험장소 : ☒ 고정시험실 ☐ 현장시험
 (주소 : 경기도 화성시 동탄산단10길 20 및 동탄산단10길 12)
 시험규격/방법 : ICC ES AC156
 -2010 [S_{DS} : 1.10 g, z/h: 1.00]
 시험결과 : 6. 시험결과 참조 (허용기준 만족)
 용도 : 품질평가용

이 성적서 위의 내용은 시험의뢰인에 의해 제공된 시료에 한하며, 용도 이외의 사용을 금합니다.

이 성적서는 KS Q ISO/IEC 17025에 따라 KOLAS 인정을 받은 분야에 대한 공인성적서입니다.

확인	작성자		기술책임자	
	성명 : 김 종 대			

※ 위 성적서는 국제시험기관인정협력체 (International Laboratory Accreditation Cooperation) 상호인정협정 (Mutual Recognition Arrangement)에 서명한 한국인정기구 (KOLAS)로부터 공인받은 분야에 대한 시험결과입니다.

2022. 11. 23.

한국인정기구 인정 **한국에스지이에스(주) 동탄시험소장**



This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 90 days only.

